



Errata

NFPA 22

Standard for Water Tanks for Private Fire Protection

2008 Edition

Reference: Equation 6.4.1.3.1(1)

Errata No.: 22-08-2

The Committee on Water Tanks notes the following error in the 2008 edition of NFPA 22, *Standard for Water Tanks for Private Fire Protection*.

1. Replace existing Equation 6.4.1.3.1(1) with the following:

$$f_t = 0.5F_y (1.0 - 0.9r + 3rd/s) \leq 0.5F_y$$

Issue Date: April 27, 2012

(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see www.nfpa.org/codelist)

Copyright © 2012 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION